# () TC Energy

# NGTL System and Foothills Pipelines Ltd.


### CUSTOMER OPERATIONS MEETING

FOR INFORMATIONAL PURPOSES ONLY



# **Forward Looking Information**

- This presentation includes certain forward-looking information. Statements that are forward-looking are based on certain assumptions and on what we know and expect today and generally include words like anticipate, expect, believe, may, will, should, estimate or other similar words.
- The information provided is for informational purposes only and is not to be relied upon for any other purpose whatsoever. The information is based upon certain assumptions that may or may not be accurate and therefore is subject to various risks and uncertainties. TC Energy shall not be liable for damages sustained as a result of any use or reliance on such information.
- The outages listed in this presentation are not an exhaustive list. Outage date, duration, and impact may be subject to change. Refer to the Daily Operating Plan (DOP) for all planned outages with potential service impact.





Outage information in this presentation may not be accurate beyond December 5, 2024 For current outage and capability information, please refer to the most recent Daily Operating Plan (DOP), the <u>Dashboard</u> and <u>bulletins</u> This meeting covers broad operational and project-related topics that impact operations on the NGTL and Foothills systems. For information on focused Commercial, Operational and Regulatory topics, please contact your <u>Marketing</u> <u>Representative</u>

# Agenda




- 1. 2024 Operational Year in Review
- 2. Review of November Operations
- 3. 2024 Remaining Outage
- 4. 2025 Operational Outlook

# 2024 Year in Review


 $\bigcirc$ 

FOR INFORMATIONAL PURPOSES ONLY

# System Throughput | Gas Year Comparison



# System Utilization | Records Achieved in 2024



17.3 BCF/D	<b>Overall NGTL System Demand (including exports)</b> on January 17, 2024
8.7 BCF/D	Intra-Provincial Demand on January 12, 2024
3.1 BCF/D	<b>OSDA Demand</b> on March 5, 2024
2.6 BCF/D	<b>Residential and Commercial Demand:</b> on January 12, 2024
1.1 BCF/D	Power Producer Demand on July 18, 2024
15.1 BCF/D	<b>Total System Receipts</b> on October 30, 2024

**Peak Storage Withdrawal was 4.3 BCF/D** on January 14, 2024 (Historical record is 4.5 BCF/D from December 6, 2013)

# NGTL Restricted Days | 2023 and 2024

2	Area	FT Restricted Days	IT Restricted Days	Unrestricted Days
	USJR	2	50	283
	EGAT	-	2	333
2	WGAT	51	-	284
4*	NEDA	2	1	332

\*Up to and including November 30

$\mathbf{p}$	Area	FT Restricted Days	IT Restricted Days	Unrestricted Days
	USJR	26	128	211
	EGAT	-	13	352
2	WGAT	59	12	294
3	NEDA	-	19	346



USJR

Increased throughput and high utilization continues



Less overall FT restricted days in comparison to 2023

# **Review of November Operations**

 $\bigcirc$ 


FOR INFORMATIONAL PURPOSES ONLY

### Meikle River D5 – Compressor Station Maintenance

#### **Background:**

- Unplanned:
  - Meikle River D5 Compressor Station Maintenance: November 26 28
- Capability communicated in DOP:
  - USJR: 360 10<sup>6</sup>m<sup>3</sup>/d
  - OSDA/NEDA: 80/125 10<sup>6</sup>m<sup>3</sup>/d
- Service Allowable:
  - USJR: 0% IT-R, 100% FT-R (Upstream of Latornell)
  - OSDA/NEDA: 0% IT-D, 71% FT-D

Bulletin Date	Effective Date	Service Allowable	Comments
	Nov 25	100% IT-R, 100% FT-R 100% IT-D, 100% FT-D	Unplanned Meikle River D5 outage
Nov 26	Nov 26 (13:00 MST)	0% IT-R, 100% FT-R (Upstream Latornell) 0% IT-D, 100% FT-D (NEDA)	Meikle River D5 unable to be reclaimed, service authorization change to both Upstream Latornell and NEDA area required to safely operate the system.
Nov 26	Nov 27 (08:00 MST)	0% IT-R, 100% FT-R (Upstream Latornell) 0% IT-D, 71% FT-D (NEDA)	Due to ongoing Meikle River D5 outage and NEDA flows exceeding capability, service authorization change to NEDA to continue to safely operate the system.
Nov 28	Nov 29 (08:00 MST)	100% IT-R, 100% FT-R (Upstream Latornell) 100% IT-D, 100% FT-D (NEDA)	Unplanned Meikle River D5 outage complete



Safe Operation

### () TC Energy

### NGTL Non-Critical Notice

Notice Type: Capacity Constraint Effective Start Date Time: Nov 26, 2024 08:49 CCT

Subject: NGTL Service (USJR IT-R, NEDA IT-D)

#### NGTL Service (USJR IT-R, NEDA IT-D)

USIR: Due to unplanned maintenance on the Meikle River D Compressor (19885252), service allowable for segments 2, 3, 4, and partial 7 (upstream Latornell) will transition from 100% IT-R and 100% FT-R to 0% IT-R and 100% IT-R and 100

#### WGAT: N/A

EGAT: Due to unplanned maintenance on the Meikle River D Compressor (19885252), service allowable in the North East Delivery Area (NEDA) will transition from 100% IT-D and 100% FT-D to 0% IT-D and 100% FT-D effective November 26, 2024 at 13:00 MST until further notice. For the purposes of the DOP that will be published today, a placeholder end date of December 2, 2024 will be used until more information is known.

Upstream James River	Receipt Area												
Effective:	October 29, 2024 at 08:00 MST	IT Allowable: 100%	IT-R	IT-S (receipt)									
Expected End:	November 26, 2024 at 13:00 MST	FT Allowable: 100%	FT-R	FT-P									
interconnects:	Aitken Creek, Big Eddy, Groundbirch East, G	Sordondale, January Creek											
Segments:	2, 3, 4, 5, 7, partial 8, and partial 9				East G	iate Delive	ry Area						
flective:	November 26, 2024 at 13:00 MST	IT Allowable: 0%	IT/R	IT-S (receipt)	Effecti	ive:		July 10, 2024 at 08:00 MST	IT Allowable: 100%	IT-D	IT-S (deliver)	)	
xpected End:	Until further notice	FT Allowable: 100%	FT-R	FT/P	Expect	ted End:		November 26, 2024 at 13:00 MST	FT Allowable: 100%	FT(P	FT-D1 FT	D2 STFT	
nterconnects:	Aitken Creek, Groundbirch East, Gordondal	ie		·	Interc	onnects:		Aeco C, Carbon, Chancellor, Crossfield East	#2, Severn Creek, Empress, M	IcNeil, Unit	y, Cold Lake, W	arwick SE	
egments:	Segments 2, 3, 4, and partial 7 (Upstream	of Latornell)			Segme	ents:		6, 10, 11, 13, 14, 15, 16, 17, 18, 19, 20, 23,	partial 21, and partial 28 (Gi	reater EGA	<u>T)</u>		
					Effecti	ive:		November 26, 2024 at 13:00 MST	IT Allowable: 100%	IT-D	IT-S (delivery	)	
					Expect	ted End:		Until further notice	FT Allowable: 100%	FT-P	FT-D1 FT	D2 STFT	
					Interc	onnects:		Aeco C, Carbon, Chancellor, Crossfield East	2, Severn Creek, Empress, Mc	Neill			
Unctrop		Lower	EGAT		5			18, 19, 20, and partial 21					
	im Latornell ions Impacted	List of Stations	s (no im	pact)	Effecti	ive:	$\sqrt{-\epsilon}$	November 26, 2024 at 13:00 MST	IT Allowable: 0%	IT-D	IT S (deliver)	)	
					Expect	ted End:		Until further notice	FT Allowable: 100%	FT-P	FT-D1 FT	D2 STFT	
					Interc	onnects:		Cold Lake, Unity, Warwick SE					
		NEDA			Segme	ents:		6, 10, 11, 13, 14, 15, 16, 17, 23, 24, and pa	rtial 28 (NEDA)				
Link to Bulleti	n: NGTL Service (USJR IT-R,	List of Stations I	mpacteo	d									
NEDA IT-D)									1 2 / 0 5 / 2 0 2 4				


# Why was this outage significant to NEDA?

### Why did this outage impact NEDA?

- Always maximizing NCC flow most efficient path for supply into NEDA
- In the winter, when NEDA demand is high, the NLAT is typically already flowing at max capability resulting in the inability to supplement a reduction of NCC flow
  - If NEDA demand is higher than the combined flow on the NCC and NLAT, service allowable would be reduced in NEDA to ensure equitability and safe operation

### Why wasn't Lower EGAT part of the restriction?

- Lower EGAT was outside of the bottlenecked area (NCC + NLAT)
- Lower EGAT flow does not reduce the NLAT capability





# 2024 Remaining Outage

 $\bigcirc$ 

FOR INFORMATIONAL PURPOSES ONLY

# 2024 Remaining Outage



- Majority of impactful preventative maintenance outages for 2024 have been completed
- One (1) potentially impactful outage is ongoing:

#### Upstream James River Receipt Area (USJR)

Outage Description	Start	End	USJR Outage Capability (10 <sup>6</sup> m³/d)	USJR Impact (10 <sup>6</sup> m <sup>3</sup> /d)	Area Outage Capability (10 <sup>6</sup> m³/d)	Outage Area Typical Flows (10 <sup>6</sup> m³/d)	Service Allowable Location/Area
Latornell A2 – Compressor Station Maintenance	<mark>2-Dec-24</mark>	<mark>6-Dec-24</mark>	<mark>372</mark>	6	<mark>277</mark>	1 715 - 735	Potential impact to FT-R USJR U/S Berland River

# **2025 Operational Outlook** (From DOP as of Wednesday, December 5)

## 2025 Outages


- Outages with the most significant impact to system capability were added to the DOP on November 6, 2024
- All known outages planned for Q1 have now been added
- We will continue to make best efforts to limit changes of dates to larger impacting outages; however, Start and End Dates, Durations, Capability, Area of impact may be revised as new information becomes available or further optimization opportunities are identified

Outages and/or maintenance work is posted to the DOP if there is reasonable expectation that the event could or will result in a change to service authorization levels.

Optimization efforts are on-going, and we will continue to focus on safety, optimizing system capacity and minimizing outage impacts.

### **Upstream James River**

Capability - Actual Flow - Historical Flow



Facility Assumptions:

• NPS 36 GPML pressure derates remain in place until June 30, 2025

### Upstream James River Receipt Area (USJR)

No impact to FT Partial impact to FT

Outage Description	Start	End	USJR Outage Capability (10 <sup>6</sup> m³/d)	USJR Impact (10 <sup>6</sup> m <sup>3</sup> /d)	Area Outage Capability (10 <sup>6</sup> m³/d)	Outage Area Typical Flows (10 <sup>6</sup> m³/d)	Service Allowable Location/Area
Otter Lake – Compressor Station Maintenance	31-Mar-25	3-Apr-25	359	18	222	1 710-730	Potential impact to FT-R USJR U/S Latornell
Groundbirch – Compressor Station Maintenance	31-Mar-25	4-Apr-25	370	7	233	1 10-730	Potential impact to FT-R USJR U/S Latornell
Alces River B3 – Compressor Station Maintenance	2-Apr-25	3-Apr-25	369	8	232	1 10-730	Potential impact to FT-R USJR U/S Latornell
Hidden Lake North – Compressor Station Maintenance	7-Apr-25	11-Apr-25	369	8	232	1 10-730	Potential impact to FT-R USJR U/S Latornell
Goodfish – Compressor Station Maintenance	7-Apr-25	11-Apr-25	361	16	224	1 10-730	Potential impact to FT-R USJR U/S Latornell
Meikle River D5 – Compressor Station Maintenance	16-Apr-25	17-Apr-25	356	21	219	110-730	Potential impact to FT-R USJR U/S Latornell
Gold Creek – Compressor Station Maintenance	28-Apr-25	2-May-25	362	13	243	1 120-150	Potential impact to FT-R USJR U/S Emerson Creek
Knight – Compressor Station Maintenance	5-May-25	9-May-25	369	6	N/A	340-370	Potential impact to FT-R USJR
Latornell – Compressor Station Maintenance	11-May-25	15-May-25	364	11	245	1 120-150	Potential impact to FT-R USJR U/S Emerson Creek
Berland River – Compressor Station Maintenance	3-Jun-25	7-Jun-25	366	7	N/A	340-370	Potential impact to FT-R USJR
Swartz Creek – Compressor Station Maintenance	7-Jul-25	13-Jul-25	366	9	N/A	340-370	Potential impact to FT-R USJR

May not be accurate beyond December 5. Please refer to the DOP on TC Customer Express for current outage information.

information updated since last meeting

Potential

impact to FT



### Upstream James River Receipt Area (USJR)

No impact to FT Potential

impact to FT

Partial impact to FT

Outage Description	Start	End	USJR Outage Capability (10 <sup>6</sup> m³/d)	USJR Impact (10 <sup>6</sup> m <sup>3</sup> /d)	Area Outage Capability (10 <sup>6</sup> m³/d)	Outage Area Typical Flows (10 <sup>6</sup> m³/d)	Service Allowable Location/Area
Alces River – Compressor Station Maintenance	18-Aug-25	22-Aug-25	369	6	238	110-130	Potential impact to FT-R USJR U/S Latornell
Meikle River C – Compressor Station Maintenance	8-Sep-25	12-Sep-25	360	17	229	710-730	Potential impact to FT-R USJR U/S Latornell
Gold Creek B3 – Compressor Station Maintenance	15-Sep-25	19-Sep-25	372	5	247	715-735	Potential impact to FT-R USJR U/S Berland River
Otter Lake – Compressor Station Maintenance	18-Oct-25	24-Oct-25	365	15	234	710-730	Potential impact to FT-R USJR U/S Latornell
Meikle River D5 – Compressor Station Maintenance	27-Oct-25	31-Oct-25	361	19	230	710-730	Potential impact to FT-R USJR U/S Latornell


May not be accurate beyond December 5. Please refer to the DOP on TC Customer Express for current outage information.

information updated since last meeting

#### Alberta-B.C. Border

(includes both NGTL and Foothills BC outages)

Capability – Actual Flow – Historical Flow -- Contracts





### West Gate Delivery Area (WGAT)


No Potential impact to FT impact to FT Partial impact to FT

Outage Description	Start	End	Capability (10 <sup>6</sup> m <sup>3</sup> /d)	Impact (10 <sup>6</sup> m³/d)	Service Allowable Location/Area
Crowsnest K – Compressor Station Maintenance	10-Mar-25	14-Mar-25	78	12	Potential Impact to FT Foothills BC
Moyie – Compressor Station Maintenance	5-May-25	9-May-25	63	26	Potential Impact to FT Foothills BC
NPS 42 WAS Mainline Loop – Pipeline Modification	7-May-25	12-May-25	69	20	Potential Impact to FT-D Alberta/BC and Alberta/Montana Borders
Burton Creek C/S – Compressor Station Maintenance	30-May-25	4-Jun-25	72	17	Potential Impact to FT-D Alberta/BC and Alberta/Montana Borders
Crowsnest – Compressor Station Maintenance	9-Jun-25	12-Jun-25	69	20	Potential Impact to FT Foothills BC
Crowsnest B – Compressor Station Maintenance	9-Jun-25	13-Jun-25	79	10	Potential Impact to FT Foothills BC
Elko – Compressor Station Maintenance	5-Aug-25	25-Aug-25	74	15	Potential Impact to FT Foothills BC
NPS 42 WAS Mainline Loop – Pipeline Maintenance	6-Aug-12	12-Aug-25	70	19	Potential Impact to FT-D Alberta/BC and Alberta/Montana Borders Segment 22 and Partial 21
Burton Creek A3 – Compressor Station Maintenance	16-Sep-25	17-Sep-25	75	14	Potential Impact to FT-D Alberta/BC and Alberta/Montana Borders
Turner Valley A1 & A2 – Compressor Station Maintenance	14-Oct-25	20-Oct-25	76	14	Potential Impact to FT-D Alberta/BC and Alberta/Montana Borders

*Note:* Outages located in the USJR area show up in the WGAT table in DOP to indicate a broad area restriction could be applied to reduce flows through the bottleneck but have been excluded from this slide to avoid duplication



# Capability – Actual Flow – Historical Flow -- Contracts





NoPotentialPartialimpact to FTimpact to FTimpact to FT

Outage Description	Start	End	Capability (10 <sup>6</sup> m <sup>3</sup> /d)	Impact (10 <sup>6</sup> m <sup>3</sup> /d)	Service Allowable Location/Area
Jenner – Compressor Station Maintenance	17-Mar-25	30-Mar-25	154	6	No impact to FT-D anticipated Empress/McNeill Borders Segments 15, 16, 17, 18, 19, 20, 23, partial 21, and partial 28
Didsbury – Compressor Station Maintenance	7-Apr-25	10-Apr-25	150	11	No impact to FT-D anticipated Empress/McNeill Borders Segments 15, 16, 17, 18, 19, 20, 23, partial 21, and partial 28
NPS 42 Foothills Zone 6 – Pipeline Maintenance	3-Jun-25	6-Jun-25	142	19	No impact to FT-D anticipated Empress/McNeill Borders Segments 15, 16, 17, 18, 19, 20, 23, partial 21, and partial 28
NPS 42 Foothills Zone 6 and 9 – Pipeline Maintenance	15-Jul-25	22-Jul-25	146	14	No impact to FT-D anticipated Empress/McNeill Borders Segments 15, 16, 17, 18, 19, 20, 23, partial 21, and partial 28

**Note:** Outages located in the USJR area show up in the EGAT table in DOP to indicate a broad area restriction could be applied to reduce flows through the bottleneck but have been excluded from this slide to avoid duplication

May not be accurate beyond December 5. Please refer to the DOP on TC Customer Express for current outage information.

information updated since last meeting

### **Oil Sands Delivery Area**

Capability - Actual Flow - Historical Flow






## Northeast Delivery Area (NEDA) Oilsands Delivery Area (OSDA)

NoPotentialPartialimpact to FTimpact to FTimpact to FT

Outage Description	Start	End	OSDA Capability (10 <sup>6</sup> m <sup>3</sup> /d)	NEDA Capability (10 <sup>6</sup> m <sup>3</sup> /d)	Impact (10 <sup>6</sup> m <sup>3</sup> /d)	Service Allowable Location/Area
NPS 24/30 North Lateral Loop 2 – Pipeline Maintenance	22-Sep-25	29-Sep-25	82	-	14	Potential impact to FT-D Segments 11, 14, 15, 16, and partial 28 Local Capability: 50 10 <sup>6</sup> m <sup>3</sup> /d Typical Flow: 62 10 <sup>6</sup> m <sup>3</sup> /d
NPS 12 Leming Lake Lateral – Pipeline Modifications	15-Oct-25	24-Oct-25	90	-	7	Potential impact to FT-D Segments 14 and partial 11 Local Capability: 18 10 <sup>6</sup> m <sup>3</sup> /d Typical Flow: 22 10 <sup>6</sup> m <sup>3</sup> /d

Note: These outages have been included in the OSDA table for the purposes of the DOP, even though their area of impact is expected to be slightly different than the standard OSDA definition

# **2025 Outage Communication Schedule**



# Happy Holidays!

Thank you for your partnership and ongoing dialogue in 2024.

We look forward to working with you in the New Year!



12/05/2024

### CONTACTS



#### MARKETING REPS


Customer Express Contacts (tccustomerexpress.com)

MINH BADAU

Chair, NGTL/FH Customer Ops 403.920.5804 minh\_badau@tcenergy.com



# **Outage Communication Tools: Order**



# **Glossary of Terms**


- DOP: Daily Operating Plan DOP
- •:• NGTL: Nova Gas Transmission Ltd.
- •:• FH: Foothills Pipeline System (BC or SK)
- •:• ISD: In-Service Date
- •:• ILI: Inline Inspection

### ·: Transportation Services

- > IT-R: Interruptible Transportation Receipt
- > IT-D: Interruptible Transportation Delivery
- **FT-R:** Firm Transportation Receipt
- **FT-D:** Firm Transportation Delivery

### ·:· Operational Areas

- USJR: Upstream James River
- 🗞 WGAT: West Gate
- 🗞 EGAT: East Gate
- Solution Solution Stress Solut
- **NEDA:** North-East Delivery Area



# **Commonly Referenced Flow Paths**

- North Montney Mainline (NMML)
- Groundbirch Mainline (GBML)
- Northwest Mainline (NWML)
- North Central Corridor (NCC)
- Grande Prairie Mainline (GPML)
- Edson Mainline (EDSML)
- Western Alberta System Mainline (WASML)
- Central Alberta System Mainline (CASML)
- Eastern Alberta System Mainline (EASML)
- South Lateral (SLAT)
- North Lateral (NLAT)