() TC Energy

NGTL System and Foothills Pipelines Ltd.


CUSTOMER OPERATIONS MEETING

FOR INFORMATIONAL PURPOSES ONLY



Forward Looking Information

- This presentation includes certain forward-looking information. Statements that are forward-looking are based on certain assumptions and on what we know and expect today and generally include words like anticipate, expect, believe, may, will, should, estimate or other similar words.
- The information provided is for informational purposes only and is not to be relied upon for any other purpose whatsoever. The information is based upon certain assumptions that may or may not be accurate and therefore is subject to various risks and uncertainties. TC Energy shall not be liable for damages sustained as a result of any use or reliance on such information.
- The outages listed in this presentation are not an exhaustive list. Outage date, duration, and impact may be subject to change. Refer to the Daily Operating Plan (DOP) for all planned outages with potential service impact.





Outage information in this presentation may not be accurate beyond March 6, 2025 For current outage and capability information, please refer to the most recent Daily Operating Plan (<u>DOP</u>), the <u>Dashboard</u> and <u>bulletins</u> This meeting covers broad operational and project-related topics that impact operations on the NGTL and Foothills systems. For information on focused Commercial, Operational and Regulatory topics, please contact your <u>Marketing</u> <u>Representative</u>

Agenda



- 1. Review of Previous Month's Operations
- 2. 2025 Operational Outlook

Review of Previous Month's Operations

 \bigcirc

FOR INFORMATIONAL PURPOSES ONLY

Alces River – Compressor Station Maintenance

Background:


- Planned:
 - Alces River Compressor Station Maintenance: February 8 9
 - Unplanned extension of the outage until February 11
 - Hidden Lake North Compressor Station Maintenance (Unplanned): February 10 11
- Capability communicated in DOP:
 - February 8-9: 376 10⁶m3/d (USJR)
 - February 10-11: 370 10⁶m3/d (USJR); 79/117 10⁶m3/d (OSDA/NEDA)

• Service Allowable:

- USJR: 0% IT-R, 100% FT-R (Upstream of Latornell)
- OSDA/NEDA: 0% IT-D, 69% FT-D

Bulletin Date	Effective Date	Service Allowable	Comments
	Feb 8	USJR: 100% IT-R, 100% FT-R NEDA: 100% IT-D, 100% FT-D	Planned Alces River outage starts as scheduled
Feb 10	Feb 10 (17:00 MST)	USJR: 0% IT-R, 100% FT-R (Upstream Latornell) NEDA: 0% IT-D, 69% FT-D	Unplanned extension of the Alces River outage Unplanned maintenance of the Hidden Lake North C/S
Feb 11	-	USJR: 0% IT-R, 100% FT-R (Upstream Latornell) NEDA: 0% IT-D, 69% FT-D	1 of 2 units reclaimed at Alces River Hidden Lake North C/S returned to service
Feb 11	Feb 12 (08:00 MST)	USJR: 100% IT-R, 100% FT-R NEDA: 100% IT-D, 100% FT-D	All facilities returned to service





03/06/2025


Berland River A1 – Compressor Station Maintenance

Background:

- Planned:
 - Berland River A1 Compressor Station Maintenance: Feb 26 Mar 19
- Capability communicated in DOP:
 - USJR: 380 10⁶m3/d
- Service Allowable:
 - USJR: 0% IT-R, 100% FT-R

Bulletin Date	Effective Date	Service Allowable	Comments
	Feb 26	100% IT-R, 100% FT-R (USJR)	Planned Berland River A1 outage starts
Feb 27	Feb 28 (08:00 MST)	0% IT-R, 100% FT-R (USJR)	Due to high system utilization and Berland River A1 outage, service authorization levels were adjusted
			Outage ongoing





2025 Operational Outlook (From DOP as of Wednesday, March 5)

Upstream James River

Capability - Actual Flow - Historical Flow



Facility Assumptions:

• NPS 36 GPML pressure derates remain in place until June 30, 2025

Upstream James River Receipt Area (USJR)

No impact to FT Potential

impact to FT

Partial impact to FT

Outage Description	Start	End	USJR Outage Capability (10 ⁶ m³/d)	USJR Impact (10 ⁶ m³/d)	Area Outage Capability (10 ⁶ m³/d)	Outage Area Typical Flows (10 ⁶ m³/d)	Service Allowable Location/Area
Berland River A1 – Compressor Station Maintenance	26-Feb-25	19-Mar-25	380	5	N/A	355-385	Potential impact to FT-R USJR
Otter Lake – Compressor Station Maintenance	31-Mar-25	3-Apr-25	365	18	222	210-230	Potential impact to FT-R USJR U/S Latornell
Groundbirch – Compressor Station Maintenance	31-Mar-25	4-Apr-25	376	7	233	710-730	Potential impact to FT-R USJR U/S Latornell
Alces River B3 – Compressor Station Maintenance	<mark>2-Apr-25</mark>	3-Apr-25	375	8	232	710-730	Potential impact to FT-R USJR U/S Latornell
Hidden Lake North – Compressor Station Maintenance	7-Apr-25	11-Apr-25	375	8	232	210-230	Potential impact to FT-R USJR U/S Latornell
Goodfish – Compressor Station Maintenance	7-Apr-25	11-Apr-25	367	16	224	710-730	Potential impact to FT-R USJR U/S Latornell
Meikle River D5 – Compressor Station Maintenance	16-Apr-25	17-Apr-25	362	21	219	710-730	Potential impact to FT-R USJR U/S Latornell
Gold Creek – Compressor Station Maintenance	28-Apr-25	2-May-25	368	13	243	730-750	Potential impact to FT-R USJR U/S Emerson Creek
Knight – Compressor Station Maintenance	5-May-25	9-May-25	375	6	N/A	355-385	Potential impact to FT-R USJR
Latornell – Compressor Station Maintenance	11-May-25	15-May-25	370	11	245	730-750	Potential impact to FT-R USJR U/S Emerson Creek
Berland River – Compressor Station Maintenance	3-Jun-25	7-Jun-25	372	7	N/A	355-385	Potential impact to FT-R USJR



Upstream James River Receipt Area (USJR)

No impact to FT Partial impact to FT

Potential

impact to FT

Outage Description	Start	End	USJR Outage Capability (10 ⁶ m³/d)	USJR Impact (10 ⁶ m ³ /d)	Area Outage Capability (10 ⁶ m³/d)	Outage Area Typical Flows (10 ⁶ m³/d)	Service Allowable Location/Area
NPS 36 Western Alberta Mainline Extension – Pipeline Maintenance	10-Jun-25	20-Jun-25	374	5	N/A	355-385	Potential impact to FT-R USJR
Pipestone Creek – Compressor Station Maintenance	2-Jul-25	17-Jul-25	375	6	238	210-230	Potential impact to FT-R USJR U/S Latornell
Swartz Creek – Compressor Station Maintenance	7-Jul-25	13-Jul-25	372	9	N/A	355-385	Potential impact to FT-R USJR
NPS 48 Grande Prairie Mainline Loop 2 – Pipeline Maintenance	22-Jul-25	28-Jul-25	374	7	256	230-250	Potential impact to FT-R USJR U/S Emerson Creek
Goodfish A1 – Compressor Station Maintenance	18-Aug-25	19-Aug-25	375	6	238	210-230	Potential impact to FT-R USJR U/S Latornell
Alces River – Compressor Station Maintenance	18-Aug-25	22-Aug-25	375	6	238		Potential impact to FT-R USJR U/S Latornell
Goodfish A2 – Compressor Station Maintenance	20-Aug-25	21-Aug-25	375	6	238	210-230	Potential impact to FT-R USJR U/S Latornell
Meikle River C – Compressor Station Maintenance	8-Sep-25	12-Sep-25	366	17	229	210-230	Potential impact to FT-R USJR U/S Latornell
Gold Creek B3 – Compressor Station Maintenance	15-Sep-25	19-Sep-25	378	5	247	215-235	Potential impact to FT-R USJR U/S Berland River
Latornell A2 – Compressor Station Maintenance	22-Sep-25	5-Oct-25	378	5	247	115-125	Potential impact to FT-R USJR U/S Berland River
Leismer East – Compressor Station Maintenance	1-Oct-25	7-Oct-25	380	6	240	210-230	Potential impact to FT-R USJR U/S Latornell
Hidden Lake North B2 – Compressor Station Maintenance	7-Oct-25	8-Oct-25	379	7	242	210-230	Potential impact to FT-R USJR U/S Latornell




Upstream James River F	No impact to FT			rtial t to FT				
Outage Description	Start	End	USJR Outage Capability (10 ⁶ m³/d)	USJR Impact (10 ⁶ m ³ /d)	Area Outage Capability (10 ⁶ m³/d)	Outage Area Typical Flows (10 ⁶ m ³ /d)	Service Allowable Loca	tion/Area
Otter Lake – Compressor Station Maintenance	18-Oct-25	24-Oct-25	371	15	234	1 10-730	Potential impact to FT-R USJR U/S Latornell	
Meikle River D5 – Compressor Station Maintenance	27-Oct-25	31-Oct-25	367	19	230	1 10-730	Potential impact to FT-R USJR U/S Latornell	



Alberta-B.C. Border

(includes both NGTL and Foothills BC outages)

Capability – Actual Flow – Historical Flow - Contracts





West Gate Delivery Area (WGAT)

NO Potential impact to FT impact to FT Partial impact to FT

Outage Description	Start	End	Capability (10 ⁶ m ³ /d)	Impact (10 ⁶ m³/d)	Service Allowable Location/Area
Crowsnest K – Compressor Station Maintenance	5-Mar-25	12-Mar-25	81	9	Potential Impact to FT Foothills BC
Moyie – Compressor Station Maintenance	5-May-25	9-May-25	63	26	Potential Impact to FT Foothills BC
NPS 42 WAS Mainline Loop – Pipeline Modification	7-May-25	12-May-25	69	20	Potential Impact to FT-D Alberta/BC and Alberta/Montana Borders
Burton Creek C/S – Compressor Station Maintenance	30-May-25	4-Jun-25	72	17	Potential Impact to FT-D Alberta/BC and Alberta/Montana Borders
Crowsnest – Compressor Station Maintenance	9-Jun-25	<mark>13-Jun-25</mark>	69	20	Potential Impact to FT Foothills BC
Crowsnest B – Compressor Station Maintenance	9-Jun-25	13-Jun-25	79	10	Potential Impact to FT Foothills BC
Elko – Compressor Station Maintenance	5-Aug-25	25-Aug-25	74	15	Potential Impact to FT Foothills BC
NPS 42 WAS Mainline Loop – Pipeline Maintenance	6-Aug-12	12-Aug-25	70	19	Potential Impact to FT-D Alberta/BC and Alberta/Montana Borders Segment 22 and Partial 21


Note: Outages located in the USJR area show up in the WGAT table in DOP to indicate a broad area restriction could be applied to reduce flows through the bottleneck but have been excluded from this slide to avoid duplication

West Gate Delivery Area (WGAT)

				No impact to	o FT	Potential impact to FT	Partial impact to FT
Outage Description	Start	End	Capability (10 ⁶ m³/d)	lmpact (10 ⁶ m³/d)	Service Allowable Location/Area		
Burton Creek A3 – Compressor Station Maintenance	16-Sep-25	17-Sep-25	75	14		al Impact to FT-D /BC and Alberta/Montana	a Borders
Turner Valley A1 & A2 – Compressor Station Maintenance	14-Oct-25	20-Oct-25	76	14		al Impact to FT-D /BC and Alberta/Montana	a Borders

Note: Outages located in the USJR area show up in the WGAT table in DOP to indicate a broad area restriction could be applied to reduce flows through the bottleneck but have been excluded from this slide to avoid duplication







East Gate Delivery Area (EGAT)

NoPotentialimpact to FTimpact to FT

Partial impact to FT

Outage Description	Start	End	Capability (10 ⁶ m³/d)	lmpact (10 ⁶ m³/d)	Service Allowable Location/Area	
					No impact to FT-D anticipated	
Jenner – Compressor Station Maintenance	17-Mar-25	30-Mar-25	154	6	Empress/McNeill Borders	
					Segments 15, 16, 17, 18, 19, 20, 23, partial 21, and partial 28	
					No impact to FT-D anticipated	
Didsbury – Compressor Station Maintenance	7-Apr-25	13-Apr-25	150	11	Empress/McNeill Borders	
					Segments 15, 16, 17, 18, 19, 20, 23, partial 21, and partial 28	
					No impact to FT-D anticipated	
Crawling Valley – Compressor Station Maintenance	2-Jun-25	8-Jun-25	155	6	Empress/McNeill Borders	
					Segments 15, 16, 17, 18, 19, 20, 23, partial 21, and partial 28	
					No impact to FT-D anticipated	
NPS 42 Foothills Zone 6 – Pipeline Maintenance	3-Jun-25	6-Jun-25	142	19	Empress/McNeill Borders	
					Segments 15, 16, 17, 18, 19, 20, 23, partial 21, and partial 28	
					No impact to FT-D anticipated	
NPS 42 Foothills Zone 6 and 9 – Pipeline Maintenance	15-Jul-25	22-Jul-25	146	14	Empress/McNeill Borders	
					Segments 15, 16, 17, 18, 19, 20, 23, partial 21, and partial 28	
					No impact to FT-D anticipated	
Schrader Creek East – Compressor Station Maintenance	15-Sep-25	24-Sep-25	154	6	Empress/McNeill Borders	
					Segments 15, 16, 17, 18, 19, 20, 23, partial 21, and partial 28	

Note: Outages located in the USJR area show up in the EGAT table in DOP to indicate a broad area restriction could be applied to reduce flows through the bottleneck but have been excluded from this slide to avoid duplication

Oil Sands Delivery Area

Capability - Actual Flow - Historical Flow





Northeast Delivery Area (NEDA) Oilsands Delivery Area (OSDA)

NoPotentialPartialimpact to FTimpact to FTimpact to FT

Outage Description	Start	End	OSDA Capability (10 ⁶ m ³ /d)	NEDA Capability (10 ⁶ m ³ /d)	Impact (10 ⁶ m ³ /d)	Service Allowable Location/Area
Paul Lake – Compressor Station Maintenance	5-Feb-25	7-Feb-25	92	-	I X	Potential impact to FT-D Segments 10, 11, and 14
NPS 24/30 North Lateral Loop 2 – Pipeline Maintenance	22-Sep-25	29-Sep-25	82	-	14	Potential impact to FT-D Segments 11, 14, 15, 16, and partial 28 Local Capability: 50 10 ⁶ m ³ /d Typical Flow: 62 10 ⁶ m ³ /d
NPS 12 Leming Lake Lateral – Pipeline Modifications	15-Oct-25	24-Oct-25	90	-	7	Potential impact to FT-D Segments 14 and partial 11 Local Capability: 18 10 ⁶ m ³ /d Typical Flow: 22 10 ⁶ m ³ /d

Note: These outages have been included in the OSDA table for the purposes of the DOP, even though their area of impact is expected to be slightly different than the standard OSDA definition

CONTACTS



MARKETING REPS

Customer Express Contacts (tccustomerexpress.com)

MINH BADAU

Chair, NGTL/FH Customer Ops 403.920.5804 <u>minh_badau@tcenergy.com</u>




Additional Resources

 \bigcirc

FOR INFORMATIONAL PURPOSES ONLY

Outage Communication Tools: Order



Glossary of Terms


- DOP: Daily Operating Plan DOP
- •:• NGTL: Nova Gas Transmission Ltd.
- •:• FH: Foothills Pipeline System (BC or SK)
- •:• ISD: In-Service Date
- •:• ILI: Inline Inspection

·: Transportation Services

- > IT-R: Interruptible Transportation Receipt
- > IT-D: Interruptible Transportation Delivery
- **FT-R:** Firm Transportation Receipt
- **FT-D:** Firm Transportation Delivery

·:· Operational Areas

- USJR: Upstream James River
- 🗞 WGAT: West Gate
- 🗞 EGAT: East Gate
- Solution Solution Stress Solut
- **NEDA:** North-East Delivery Area



Commonly Referenced Flow Paths

- North Montney Mainline (NMML)
- Groundbirch Mainline (GBML)
- Northwest Mainline (NWML)
- North Central Corridor (NCC)
- Grande Prairie Mainline (GPML)
- Edson Mainline (EDSML)
- Western Alberta System Mainline (WASML)
- Central Alberta System Mainline (CASML)
- Eastern Alberta System Mainline (EASML)
- South Lateral (SLAT)
- North Lateral (NLAT)

Plant Turnaround Information

- All known outages for 2025 have now been added to DOP
- Customer Plant Turnaround Information is important to TC for planning outage execution and determining service-level impact required
- Customers can use the Plant Turnaround Information Form or send us an email to provide us with their turnaround details.
- We accept plant turnaround information any time throughout the year.
- All customer specific information received will remain strictly confidential within the outage planning and coordination teams

Report your maintenance and turnaround schedules for the remainder of 2025 and beyond Click <u>HERE</u> for the PTA form

Where to send the form: ab bc ops planning@tcenergy.com

FOR INFORMATIONAL PURPOSES ONLY

PLANT TURNAROUND INFORMATION FORM

TC Energy

Date:	Email to: <u>ab_bc_ops_planning@tcenergy.com</u>
Your Contact Information:	
Your Name:	
Company Name:	
Phone:	
Secondary Phone (Optional):	
Email:	

Please select one of the following:

Information for new Plant Turnaround

Update to existing Plant Turnaround information

Plant Turnarou	lant Turnaround Information:								
NGTL Meter St	ation Name:								
NGTL Meter St	ation Number:								
Start Date:			End Date:						
Start Time:			End Time:						
Type of Plant T	urnaround:								
Complete T	urnaround (Zero Flow)								
Partial Turn	around:								
Expect	ed Flow during turnarou	nd:	10 ³ m ³ /d						
Typical	Flow: 10 ³ m ³ /c	ł							

Additional Comments:		

Email this form to: <u>ab_bc_ops_planning@tcenergy.com</u>. Direct any questions to the Pipeline @ (403) 920-7473.